

# MT. OLYMPUS IMPROVEMENT DISTRICT

CHAIRMAN  
AMI ANDERSON NEFF

3932 SOUTH 500 EAST  
SALT LAKE CITY, UTAH 84107-1895  
PHONE (801) 262-2904  
FAX (801) 265-0551

GENERAL MANAGER  
KERRY S. EPPICH

TRUSTEES  
GILES DEMKE  
C. KIM BLAIR

COUNSEL  
KIRTON & MCCONKIE

## RECONNECT PROCEDURES

Disclaimer: The District does not recommend the use of sanitary sewer laterals which are older than 50 years. See the District Standards and Specifications for additional information.

If choosing to reconnect to an existing lateral 50 years old or more, **two separate inspections must take place** and the following procedures must be followed:

1. Has a CCTV Inspection with a District Inspector taken place? If not, call (801) 262-2904 and press option 3 to schedule the ***CCTV Inspection*** (the first inspection). The Contractor is responsible for providing a high-quality CCTV camera for the inspection. The contractor must also provide a source of water and camera skids for the inspection.
2. If the existing old lateral does not pass inspection the District Inspector will discuss possible options with the Contractor.
3. Once the existing old lateral has passed inspection. The permit for a reconnection can be obtained by bonded Contractors. Call (801) 262-2904 and press option 3 to schedule the ***Reconnection Inspection*** (the second inspection). Work on the reconnection (i.e., laying new SDR 35 pipe, furnishing and installing 3/4" minus gravel, shielded Ferncos, etc.) should not take place until the CCTV Inspection is passed off and a Reconnection Permit is obtained.